

## Attachment 4 – EPA Secondary Drinking Water Standards

(Environmental Health samples and testing were compared to these standards)

### Table of Secondary Standards

<b>Contaminant</b>	<b>Secondary MCL</b>	<b>Noticeable Effects above the Secondary MCL</b>
Aluminum	0.05 to 0.2 mg/L*	colored water
Chloride	250 mg/L	salty taste
Color	15 color units	visible tint
Copper	1.0 mg/L	metallic taste; blue-green staining
Corrosivity	Non-corrosive	metallic taste; corroded pipes/ fixtures staining
Fluoride	2.0 mg/L	tooth discoloration
Foaming agents	0.5 mg/L	frothy, cloudy; bitter taste; odor
Iron	0.3 mg/L	rusty color; sediment; metallic taste; reddish or orange staining
Manganese	0.05 mg/L	black to brown color; black staining; bitter metallic taste
Odor	3 TON (threshold odor number)	"rotten-egg", musty or chemical smell
pH	6.5 - 8.5	low pH: bitter metallic taste; corrosion high pH: slippery feel; soda taste; deposits
Silver	0.1 mg/L	skin discoloration; graying of the white part of the eye
Sulfate	250 mg/L	salty taste
Total Dissolved Solids (TDS)	500 mg/L	hardness; deposits; colored water; staining; salty taste
Zinc	5 mg/L	metallic taste

\*mg/L is milligrams of substance per liter of water.